



4 3 2 1

600
PSI



VIEW AT CENTER SUPPORT
CENTER VESSEL ON 2 OR 3 SUPPORTS
AT SPAN(S) "S": 3 SUPPORTS REQUIRED
FOR LENGTHS 4 AND OVER

CAUTION: INCORRECT MANIFOLDING
WILL CAUSE SEVERE LOCAL STRESS
AROUND PORT AND MAY RESULT IN
LEAKS AND PREMATURE FAILURE;
TAKE EVERY PRECAUTION LISTED
ON REVERSE, SEE INSTALLATION
INSTRUCTIONS FOR FURTHER DETAILS



WARNING
INTERNAL PORT PRESSURE
NOT TO EXCEED 125 PSI.

SECTION THROUGH END CLOSURE

- NOTES:-
- MAX. ANGULAR VARIATION BETWEEN ANY PORTS ±0.5°.
 - DIMENSION IN INCHES (MM APPROX.)
 - SHELL EXTERIOR COATED WITH WHITE, HIGH GLOSS POLYURETHANE PAINT.
 - NOT TO BE USED FOR CONSTRUCTION UNLESS CERTIFIED.
 - ITEM 13 DOWNSTREAM ONLY.
 - * GRADE CF3M PER ASME SA-351.
 - ** WEIGHTS GIVEN IN THE TABLE ARE FOR HIGHEST CONFIGURATION AND WILL VARY WITH CHANGE IN CONFIGURATION.

| DWG REF | QTY | PART NUMBER | DESCRIPTION | MATERIAL |
|--|-----|---------------|---------------------------|---|
| SHELL | | | | |
| 1 | 1 | ORDER SECTION | SHELL | Filament Wound Epoxy/Glass composites - Head locking grooves integrally wound in place. |
| 2 | A/R | | F/C Port | CF3M* |
| 3 | A/R | | F/C Port Seal | Ethylene Propylene . |
| HEAD - NON CODED | | | | |
| 4 | 2 | 96244 | Elliptical Head Assy. | Engineering Thermoplastic. |
| 5 | 2 | 96000 | Head Seal | Ethylene Propylene - O - Ring |
| HEAD INTERLOCK | | | | |
| 6 | 2 | 47336 | Quick Release Spiral Ring | 316 Stainless Steel. |
| VESSEL SUPPORT | | | | |
| 7 | 2* | 52169 | Saddle | Engineering Thermoplastic. |
| 8 | 2* | 45042 | Strap Assy. | 304 Stainless Steel-PVC Cushion. |
| 9 | 4 | 46265 | Strap screw. | 5/16-18 UNC, 18-8 Stainless Steel. |
| ELEMENT INTERFACE | | | | |
| 10 | 2 | A/R | Adapter | Engineering Thermoplastic. |
| 11 | 2 | 52245 | Adapter seal | Ethylene Propylene - O - Ring |
| 12 | 4 | A/R | PWT Seal | Ethylene Propylene - O - Ring |
| 13 | 1 | 97014 | Thrust Cone | Engineering Thermoplastic. |
| + 3 each furnished with length code 4,5,6,7 & 8. | | | | |

| Dash Length | L IN(MM) | P IN(MM) | S IN(MM) | Approx Weight LB(KG)** |
|-------------|---------------|------------|--------------|------------------------|
| -1 | 59.75 (1518) | 47 (1194) | 20X1 (502) | 77 (35) |
| -2 | 99.75 (2534) | 87 (2210) | 56X1 (1422) | 101 (46) |
| -3 | 139.75 (3550) | 127 (3226) | 80X1 (2032) | 126 (57) |
| -4 | 179.75 (4566) | 167 (4242) | 64X2 (1626) | 151 (68) |
| -5 | 219.75 (5582) | 207 (5258) | 78X2 (1981) | 174 (79) |
| -6 | 259.75 (6598) | 247 (6274) | 92X2 (2337) | 199 (90) |
| -7 | 299.75 (7614) | 287 (7290) | 106X2 (2692) | 221 (100) |
| -8 | 339.75 (8630) | 327 (8306) | 120X2 (3048) | 246 (111) |

PENTAIR
CODELINE®

| | | | | |
|---------------|--------------|---|---------|--------------|
| DRAWN DATE | KR 05 NOV 07 | MODEL - 80S60(NON-CODED) MEMBRANE HOUSING | | |
| CHECKED DATE | MD 05 NOV 07 | ECN | 3452 | REV. L |
| APPROVED DATE | SS 05 NOV 07 | DWG. NO. | 99174 | SHEET 1 OF 2 |
| | | SCALE | NONE | SIZE A3 |
| | | DATE | 10APR15 | |

4 3 2 1

RATING:

DESIGN PRESSURE.....600 PSIG at 190°F
 (4.1 MPa at 88°C)
 MIN. OPERATING TEMP.....20°F
 (-7°C)
 FACTORY TEST PRESSURE.....900 PSIG
 (6.2 MPa)
 QUALIFICATION PRESSURE.....3600 PSI
 (24.8 MPa)

INTENDED USE:

The CodeLine 80S60 Non Coded Fiberglass RO Pressure Vessel is designed for continuous, long term use as housing for reverse osmosis membrane elements to desalt typical brackish waters at pressures up to 600 psi. Any make of eight-inch nominal diameter spiral-wound element is easily accommodated; the appropriate interfacing hardware for the element specified is furnished with the vessel.

The Shell of CodeLine 80S60 Non Coded vessel is designed in accordance with the engineering standards of the Boiler and Pressure Vessel Code of the American Society of Mechanical Engineers (ASME) as per Section X.

The CodeLine 80S60 Non Coded vessel must be installed operated and maintained in accordance with the listed precautions and good industrial practice to assure safe operation over a long service life.

The high performance Filament wound FRP shell must be allowed to expand under pressure; undue restraint at support points or piping connections can cause leaks to develop in the shell. This side-ported vessel requires special precautions in mounting and connection to piping so that the vessel will not be subjected to excessive stress due to bending moments acting at the side openings in the fiberglass shell. The end closure, incorporating close fitting, interlocking metal components, must be kept dry and free of corrosion; deterioration can lead to catastrophic mechanical failure of the head.

Pentair will assist the purchaser in determining the suitability of this standard vessel for their specific operating conditions. The final determination however, including evaluation of the standard material of construction for compatibility with the specific corrosive environment, shall be the responsibility of the purchaser. Alternate materials with enhanced corrosion resistance are available on special order.

Specifications are subject to change without notice.

PRECAUTIONS:

- DO...read, understand and follow all instructions; failure to take every precaution will void warranty and may result in vessel failure
- DO...mount the shell on horizontal members at span "S" using compliant vessel supports furnished; Shim saddles if required. Tighten hold down straps just snug
- DO...align and center side ports with the manifold header. Correct, causes of misalignment in a row of vessels connected to the same header
- DO...use flexible type IPS grooved-end pipe couplings, at side ports; allow full, 0.125 inch gap between port and piping, and position piping to maximize flexibility of connection.
- DO...provide flexibility in, and support for piping manifolds so that vessel can grow in length under pressure without undue restraint; provide additional flexible joints in large pipes leading to manifold header.
- DO...provide overpressure protection for vessel set at not more than 105% of design pressure
- DO...inspect end closures regularly; replace components that have deteriorated and correct causes of corrosion
- DO... Lubricate seals sparingly, using nonpetroleum Based lubricants, i.e. Parker Super O-lube®, Glycerin or suitable silicone based lubricants.
- DO NOT...work on any component until first verifying that pressure is relieved from vessel
- DO NOT...make rigid piping connections to ports or clamp vessel in any way that resists growth of fiberglass shell under pressure; ***ΔDIA = 0.015 in. (0.4mm) and ***ΔL = 0.2 in. (6mm) for a length code -8 vessel
- DO NOT... hang piping manifolds from ports or use vessel in any way to support other components
- DO NOT...tighten Permeate Port connection more than one turn past hand tight
- DO NOT... operate vessel without connecting both Permeate Ports internally to complete set of elements or otherwise plug ports internally so that external piping connection is not subjected to feed pressure
- DO NOT...install Spacer on downstream end of vessel
- DO NOT...operate vessel without Thrust Cone installed downstream
- DO NOT...pressurize vessel until double-checking to verify that the Locking Ring is in place and fully seated.
- DO NOT...operate vessel at pressure and temperature in excess of its rating.
- DO NOT...operate vessel with permeate pressure in excess of 125 psi at 190°F (0.86 MPa at 88°C).
- DO NOT...tolerate leaks or allow end closures to be routinely wetted in any way
- DO NOT...operate outside the pH range 3-11.

ORDERING:

Using the chart below, please check the features you require

VESSEL LENGTH CODE – please check one

MODEL 80S60 Non Coded -1 -2 -3 -4 -5 -6 -7 -8

MEMBRANE BRAND AND MODEL

Please supply adapters for the following membrane brand and specific model
 Brand _____ Model _____

CERTIFICATION REQUIRED

- CE Marked Standard.
- Certified by Pentair.

PERMEATE PORT CONFIGURATION:

- Standard. 1" FNPT & 1.5" IPS GROOVED NORYL HEAD.
- Optional .1" BSP F/JIS F Parallel Thread & 1.5" IPS GROOVED NORYL HEAD.

STRAP ASSEMBLY

- Standard SS304
- Optional SS316
- Optional SS316L

FEED/CONCENTRATE PORT SELECTION

Material of Construction Standard CF3M Optional Duplex SS (CD3MN)
 Optional Super Duplex SS (CD3MWCuN)

Configuration Standard - CF3M 1D5D


- Optional – Multi ports :(Refer SPEC.SHEET/PM/1.5"-3" for Multi port selection)
 2.5" Ports not available in 90° Configuration.

Serial number end
 Opposite end

| PORT SIZE CODE | |
|----------------|-----------------|
| D | 1½" GROOVED END |
| E | 2" GROOVED END |
| F | 2½" GROOVED END |

For complete information on proper use of the vessel
 Please refer to the 80S Series USER'S GUIDE 94182.

| ADAPTER KITS | |
|--------------|-------------|
| UP STREAM | DOWN STREAM |
| | |



CODELINE BODY LABELS ARE PLACED AT 90° TO SERIAL NUMBER END AND AT 270° ON THE OPPOSITE SIDE END